

## THE APPROACH TO CONDUCTING EXPERIMENTAL STUDIES WITH LOGIC CONTROL SYSTEMS

*Abdullaeva Dilnavoz Khusniddinovna*  
*Bukhara Engineering-Technological Institute*

The article is devoted to solving practical problems of design and implementation of experimental studies with logical control systems. The research carried out to verify the possibility of commercial operation for logic control systems.

**Keywords:** logical part of control systems, PLC, NC, automation

**Introduction.** Programmable logic controllers (PLCs) are the basic elements of industrial automation systems today. All industrial control systems, monitoring systems, performance, control, telemetry systems, accident prevention and many others were built based on them. Besides, modern PLCs are of great importance in NC systems. The modern level of development of programmed numerical control systems allows using the software-implemented logic controller (SoftPLC) to solve a logical problem in frame of the general software of NC systems without involvement of additional equipment and system software of programmable controllers, which are constitutive part of almost any modern NC system [1]. This approach reduces the cost of control system and provides a number of advantages, including adding new functionality and modernization of the controller in a short time; creation of cross-platform application depending on current technological task; potential to reduce start-up time, etc.

During the experimental research, which was carried out in order to gain practical experience in the use of logical control systems based on Soft PLC controllers [2, 3], the structures of individual software and hardware components of control systems have been improved and specified, as well as experience in setting up and debugging control systems of a new class has been gained. The possibility and feasibility of industrial operation of the systems has been established.

**Main part.** To solve the problem of choosing a hardware platform and compatibility of hardware and software, a complex test bench has been developed that can be reoriented to work with various hardware platforms in a short period of time [4]. The following were selected as control objects:

- group of eight segment indicators with control elements (buttons) – “Control object 1”. This control object allows checking the operation of logic control system with discrete input (control buttons) and output (indicator segments) signals;
- Servo drive unit based on EtherCAT protocol – “Control object 2”. The control object allows checking the function blocks and controlling motion algorithms of logic control system.

The described test bench is a fast-reconfigurable object in which there are permanently plugged and pluggable elements. The main task of logical control systems is to control electrical automation systems, in which more than 70% of the signals are discrete, therefore hardware “inputs/outputs” and “Control object 1” are permanently

plugged elements, which also include a terminal computer with installed programming environment [5].

Depending on the tests being conducted, one of three hardware platforms with installed control kernel are connected to the test bench: a) single-board computer; b) personal computer; c) computer of industrial version. All equipment is aggregated into a single network through a network concentrator (Hub). "Control object 2" is used to check the operability of the logical control system in motion control tasks.

The terminal computer is connected via Ethernet network to the basic computing module on which the kernel of the logical control system is installed [6]. The developed logic control program is send to the system kernel, and then the debugging of program and the subsequent launch of the debugged version of the logic control program is carried out. Then, communication with the terminal computer is necessary only for visual display of the operation of the logical control program during the work of the test bench.

In accordance with the testing methodology, one of the variants of the developed distributed model of the test bench was selected for experimental research. In the course of bench tests, a variant of experimental test bench with a calculator based on single-board computer and control object in the form of group of 8-segment indicators was chosen. The test bench is additionally equipped with power elements: a) the power supply has the characteristics of + 24V, 10 A for hardware "inputs/outputs"; b) + 5V, 5 A for a single-board computer.

On this modification of test bench, the following were tested:

- the ability to operate a logic control system based on a single-board computer with discrete "inputs/outputs";
- performance of selected system configuration.

In accordance with the testing methodology, bench tests were carried out, during which the following results were obtained:

- conformity and stability during the joint work of the development environment for logical control programs and the logical control kernel was achieved, which allows loading and debugging programs of even large size (over 20 thousand functional blocks);
- correct operation of the logic control system with hardware inputs/outputs when processing discrete and analog external signals was confirmed;
- mean time between failures of the logical control kernel is more than 1000 hours, which meets the requirements for industrial systems;
- execution time of the logical control cycle when working in a real-time operating system is less than 10 ms.

These results meet the requirements of industrial systems working in hard real-time mode.

One of the possible variants for using logic control system is a software-implemented *logic controller integrated into the NC system*. In this case, the kernel of the logical control system is integrated into the software-mathematical support of the kernel of NC system. The developed programming environment for logical control systems can be either integrated into the terminal of the NC system, or work autonomously.

## **Conclusions**

1. Logical control system built into NC mathematical-software is efficient, highly reliable, fault-tolerant, easily integrated into modern CNC systems. This allows considering the developed logical control system can be used on technological equipment in industrial environment.

2. Implementation of logical control cycle in separate thread does not lead to increase in the execution time of the cycle for solving a geometric NC task.

3. Integration of development environment for logic control programs into the terminal of NC system did not lead to emergencies during the operation of terminal. The terminal has a stable connection with NC kernel.

## **List of references**

1. Shemelin V.K., Nezhmetdinov R.A. Application of “client-server” technology in design of Soft PLC type controller for solving logical problem in frame of NC systems // Automation. Modern technologies. 2010. No.3. P. 20-24.
2. Nezhmetdinov R.A., Shemelin V.K. Improving the quality of architectural solutions of NC systems based on software-implemented controller of SoftPLC type // Automation. Modern technologies. 2008. No.6. P. 33-36.
3. Kozak N.V., Abdullaev R.A., Kovalev I.A., Chervonnova N.Yu. Implementation of logical task of NC and task of industrial safety based on SoftPLC external computational modules // Automation in industry. 2016. No.5. P.28-30.
4. Abdullaeva D.Kh. Development of the network model of the experimental stand for testing the operability of logic control systems. // Toronto, Canada conference-2022 Proceedings. International conference on developments in education. April15th-16th, 2022. P 161-163.
5. Abdullayeva D.H., Sayliev II., Nezhmetdinov R.A., Nezhmetdinova R.A. Solution of logical problem of numerical program control using the software-implemented. // AGRITECH-V-2021 IOP Conf. Series: Earth and Environmental Science 839 (2021) 032038. P 1-7.
6. Urinov N., Nezhmetdinov R., Abdullayeva D. Experimental stand for checking of serviceability of logical control system integrated in the composition of the numerical program control system. // International Journal of Advanced Research in Science, Engineering and Technology vol. 7, Issue 5, May 2020. P 13620-13624.